

6.5kWh Battery Pack Specification



DATE

Revision Date : Oct. 21. 2016

MODEL P/N

48V 6.5kWh: R48126P3S



CONTENTS

| 1. Features | 2 |
|-------------------------------------|--------|
| 2. Outline Dimensions | 2 |
| 3. Technical Data | 3 |
| 4. Product Composition | 4 |
| 5. LED indicators | 4 |
| 6. Packaging | 5 |
| 7. General Precautions | 7 |
| 8. Battery Handling Guide | 8 |
| 9. Response to Emergency Situations | 9 |
| 10. Troubleshooting | 10 |

1. Features


RESU 6.5 battery pack designed for photovoltaic systems is easily adaptable energy storage solution. With RESU Plus, all 48V models can be "cross-connected" with one other 48V unit of any capacity.

- ※ RESU Plus is an expansion kit specially designed for 48V models. Number of expandable battery units : up to 2
 - Compact and light weight
 - Density Powerful Performance : World Best Energy Density
 - Easy and Flexible installation
 - : Easy wall-mounted or floor-standing installation enable
 - : Diverse Matched Inverters Available
 - $\hfill\square$ BMS firmware can be updated easily by using SD Card

2. Outline Dimensions

656

C LG



| Physical Characteristics | | | | |
|--------------------------|---------|------------|--|--|
| Model P/N | | R48126P3S | | |
| Width mm (in) | | 452 (17.8) | | |
| Depth | mm (in) | 120 (4.7) | | |
| Height | mm (in) | 656 (25.8) | | |
| Weight | Kg (lb) | 52 (114.6) | | |





(Unit : mm)



TECHNICAL INFORMATION

3. Technical Data

| Electrical Characteristics | | |
|---|----------------------------------|--|
| Total Energy Capacity | 6.5 kWh | |
| Usable Energy Capacity | 5.9kWh | |
| Battery Capacity | 126 Ah | |
| Voltage Range | 42.0~58.8V _{DC} | |
| Nominal Voltage | 51.8V _{DC} | |
| Max. Charge/Discharge Current | 100A | |
| Max. Charge/Discharge Power ¹⁾ | 4.2kW | |
| Peak Power ²⁾ | 4.6kW for 3 sec. | |
| Peak Current | 109.5 A for 3 sec. | |
| Battery Pack Round-Trip Efficiency | >95% (under specific condition) | |
| Communication Interface | CAN 2.0B | |
| DC Disconnect | Circuit Breaker, Contactor, Fuse | |

Operating Conditions

| Installation Location | Indoor(Wall-Mounted) / Outdoor |
|-------------------------------------|--------------------------------|
| Operating Temperature | -10~45°C |
| Operating Temperature (Recommended) | 15~30°C |
| Storage Temperature | -30~60°C |
| Humidity | 5%~95% |
| Altitude | Max. 2,000m |
| Cooling Strategy | Natural Convection |

Reliability & Certification

| | Cell | UL1642 | |
|------------------------------------|--------------|--|--|
| Safety | Battery Pack | CE / RCM / FCC / TUV (IEC 62619) / UL1973 | |
| Hazardous Materials Classification | | Class 9 | |
| Transportation | | UN38.3 (UNDOT) | |
| Ingress Rating | | IP55 | |
| | . 25% | | |

% Test Conditions - Temperature 25°C


1) LG Chem recommends 2.2kW for maximum battery lifetime

2) Peak Current excludes repeated short duration (less than 3 sec.) of current pattern.



4. Product Composition


The exploded view



5. LED indicators

The LED indicators on the front of the battery pack show its operating state:


- ON : This indicator is lit when the circuit breaker switch is in the ON position.
- Charging : This indicator is lit while the battery pack is charging.
- Discharging : This indicator is lit while the battery pack is discharging.
- Warning : This indicator is lit when the battery pack is in a warning state.





6. Packaging

6-1. Pack Labels




🕒 LG Chem

2,160mm

The battery Box packaging was approved the International Maritime Dangerous Goods regulation certification. (IMDG Code P903, IATA DGR PI965)


6-2. Box packaging specification



| | Size | Weight | Packing | Outer packing |
|---------|----------------|--------|---------|------------------|
| | L x W x H (mm) | (kg) | Qty. | material |
| Product | 656x452x120 | 52 | 1 | - |
| Box | 710x670x180 | 7 | 1 | Corrugated paper |
| PU * | 710x670x180 | 59 | 1 | Corrugated paper |

* PU : Packing Unit

Packing Unit




Handling Unit

| | Size | Weight | Packing | Outer packing |
|---------|-----------------|--------|---------|------------------|
| | L x W x H (mm) | (kg) | Qty. | material |
| Product | 656x452x120 | 52 | 10 | - |
| PU | 710x670x180 | 59 | 10 | Corrugated paper |
| Pallet | 720x1,400x120 | 13 | 1 | Wooden |
| HU * | 720x1,400x1,020 | 603 | 1 | - |

* HU : Handling Unit

40Ft Container Loading Information

| R | ESU 6.5 | | Remark |
|--------------|----------|-------|-----------------------------------|
| Container | Pallets | 24 | - |
| Loading (ea) | Products | 240 | 240ea/CT = 10ea/Pallet×24Pallets |
| Weight (ton) | | 17.47 | 14,472kg = 603kg/Pallet×24Pallets |



20Ft Container Loading Information

5,600mm

| | 5 | | |
|--------------|----------|------|----------------------------------|
| R | ESU 6.5 | | Remark |
| Container | Pallets | 12 | - |
| Loading (ea) | Products | 120 | 120ea/CT = 10ea/Pallet×12Pallets |
| Weight (ton) | | 7.23 | 7,236kg = 603kg/Pallet×12Pallets |
| Side View | | | Front View |
| | | | |
| 1 2 | 3 4 | | 1 2 3 |



For safety reasons, installers are responsible for familiarizing themselves with the contents of this document and all warnings before performing installation.

7. General Precautions

Failure to observe the precautions described in this section can cause serious injury to persons or damage to property.

Risks of explosion

- Do not subject the battery pack to strong impacts.
- Do not crush or puncture the battery pack.
- Do not dispose of the battery pack in a fire.

Risks of fire

- Do not expose the battery pack to temperatures in excess of 60°C.
- Do not place the battery pack near a heat source, such as a fireplace.
- Do not expose the battery pack to direct sunlight.
- Do not allow the battery connectors to touch conductive objects such as wires.

Risks of electrical shock

- Do not disassemble the battery pack
- Do not touch the battery pack with wet hands
- Do not expose the battery pack to moisture or liquids
- Keep the battery pack away from children and animals

Risks of damage to the battery pack

- Do not allow the battery pack to come in contact with liquids.
- Do not subject the battery pack to high pressures.
- Do not place any objects on top of the battery pack.



Over-voltages or wrong wiring can damage the Battery Pack and cause deflagration, which can be extremely dangerous. Do not install the battery pack on flammable construction materials, in areas, where highly inflammable materials are stored, or in potentially explosive environments. Work with the cover removed must be carried out by a qualified electrician. High contact voltages are present in the device.

8. Battery Handling Guide

- Do not expose battery to temperature over 50°C and open flame.
- Do not damage the unit in such ways as dropping, deforming, impacting, cutting or penetrating with a sharp object. It may cause a leakage of electrolyte or fire.
- Do not connect anode and cathode terminal block opposite direction.
 It may cause severe short circuits.
- Do not charge or discharge damaged battery.
- Do not place any kind of foreign matters on the cooling path.
- Do not put the battery module upside down on the ground.
- Hold with insulated gloves when carrying the battery modules.
- Do not disconnect, disassemble or repair by unauthorized persons. Services must be made by authorized engineers only.
- All types of breakdown of the product may lead to a leakage of electrolyte or flammable gas.
- Do not place the product nearby flammables. It may lead to fire or explosion in case of accident.
- Keep out of reach of children or animals.
- Keep the product away from moisture or liquid. Do not touch or use if liquid is spilled on the product.
- Store at cool and dry place



9. Response to Emergency Situations

The RESU battery pack comprises multiple batteries that are designed to prevent hazards resulting from failures. However, LG Chem cannot guarantee their absolute safety.

Leaking batteries

If the battery pack leaks electrolyte, avoid contact with the leaking liquid or gas. Electrolyte is corrosive and contact may cause skin irritation and chemical burns. If one is exposed to the leaked substance, do these actions:

- Inhalation

: Evacuate the contaminated area, and seek medical attention immediately.

- Eye contact

: Rinse eyes with flowing water for 15 minutes, and seek medical attention immediately.

- Skin contact

- : Wash the affected area thoroughly with soap and water, and seek medical attention immediately.
- Ingestion
 - : Induce vomiting, and seek medical attention immediately.

Fire

In case of a fire, make sure that an ABC or carbon dioxide extinguisher is nearby. If a fire breaks out where the battery pack is installed, do these actions:

- Extinguish the fire before the battery pack catches fire.
- If the battery pack has caught fire, do not try to extinguish the fire. Evacuate people immediately.
- % The battery pack may catch fire when heated above 150°C.

If the battery catches fire, it will produce noxious and poisonous gases. Do not approach.

Wet batteries

If the battery pack is wet or submerged in water, do not try to access it. Contact LG Chem or your distributor for technical assistance.

Damaged batteries

Damaged batteries are dangerous and must be handled with extreme caution. They are not fit for use and may pose a danger to people or property. If the battery pack seems to be damaged, pack it in its original container, and then return it to LG Chem or your distributor.

[※] Damaged batteries may leak electrolyte or produce flammable gas. If you suspect such damage, immediately contact LG Chem for advice and information.



10. Troubleshooting

Check the indicators on the front to determine the state of the battery pack. A warning state is triggered when a condition, such as with voltage or temperature, is beyond design limitations. The battery pack's BMS periodically reports its operating state to the inverter.

When the battery pack falls outside prescribed limits, it enters a warning state. When a warning is reported, the inverter immediately stops operation. Use the monitoring software on the inverter to identify what caused the warning. The possible warning messages are as follows

- Battery Over Voltage
- Battery Under Voltage
- Battery Over Temperature
- Battery Under Temperature
- Battery Discharge Over Current
- Battery Charge Over Current
- BMS Internal Communication
- Battery Cell Voltage Imbalance

The abnormal state is cleared when the battery pack recovers normal operation.

% For a serious warning, if no proper corrective actions are taken by the inverter, the battery pack's circuit breaker automatically trips to protect itself.

10-1. Contact Information

Use the contacts below for technical assistance. These phone numbers are available only during business hours on weekdays.

| | Telephone | Email |
|-------------------------|------------------|------------------------------|
| Europe | +49 162 2970918 | aburkert@lgchem.com |
| USA | +1 248 808 0016 | CSNorthAmericaESS@lgchem.com |
| Australia | +61 1300 178 064 | m_AUservice@lgchem.com |
| Korea and Other regions | +82 43 219 2695 | soongkyu@lgchem.com |

SolutionPartner

