



Certificate of Conformity

Certificate No.: 2188AP050446005
Equipment: Grid-connected PV Inverter
Brand Name:  **GOODWE**
your solar engine
Test Model No.: GW36K-MT, GW30K-MT, GW25K-MT
Applicant: Jiangsu GoodWe Power Supply Technology Co., Ltd.
No.90 ZiJin Rd., New District, Suzhou,215011,China
Report No.: PV181008N021-R1, PV181008N021-1-R1, PV181008N021-2-R1,
PV181008N021-3-R1, 181106064RT

Use in accordance with regulations:

The inverters are tested for functional safety, grid protection, specified environmental influences and efficiency. For detailed information, please watch the corresponding test reports.

Applied rules and standards

IEC 60068-2-1:2007	Environmental testing – Part 2-1: Tests – Test A: Cold
IEC 60068-2-2:2007	Environmental testing – Part 2-2: Tests – Test B: Dry heat
IEC 60068-2-14:2009	Environmental testing – Part 2-14: Tests – Test N: Change of temperature
IEC 60068-2-30:2005	Environmental testing – Part 2-30: Tests –Test Db and guidance: Damp heat, cyclic (12 + 12-hour cycle)
IEC 60068-2-64:2008	Environmental testing – Part 2-64: Tests –Test Fh: Vibration, broadband random and guidance
IEC 61683:1999	Photovoltaic systems – Power conditioners – Procedure for measuring efficiency
EN 50530:2010	Overall efficiency of grid connected photovoltaic inverters
IEC 61727:2004	Characteristics of the utility interface
IEC 62116:2014	Islanding prevention measures for utility-interconnected photovoltaic inverters

Name: Ken Chan
Technical Manager/ New Energy Team
Date: 2021-09-23

This document shall not be reproduced, except in full, without the written approval of Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch.
Information given in this document is related to the tested specimen of the described electrical sample.