

# CERTIFICATE of Conformity



Registration No.: A3 50619113 0001

Report No.: CN24PLIR 001

Holder: SolaX Power Network Technology  
(Zhe jiang) Co., Ltd.  
No.288 Shizhu Road  
Tonglu Economic Development Zone  
Tonglu City,  
Zhejiang Province 310000  
P.R. China

Product: PV-Inverter  
(Hybrid Inverter)

Identification: Type Designation : X3-IES-4K X3-IES-5K X3-IES-6K  
X3-IES-8K X3-IES-10K X3-IES-12K  
X3-IES-15K  
Serial Number : H35A15J7G44003  
Firmware Version : DSP: 2.07; ARM: 2.03  
Remark(s) : Refer to report CN24PLIR 001 for details.

Tested acc. to: EN 50549-1:2019  
EN 50549-1:2019+A1  
EN 50549-10:2022  
2016/631 EU - (NC RfG)

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Durch die DAkkS nach  
DIN EN ISO/IEC 17065:2013  
akkreditierte Zertifizierungsstelle  
Die Akkreditierung gilt nur für den in der  
Urkundenanlage D-ZE-14169-01-02  
aufgeführten Akkreditierungsumfang.

Certification Body

Date 16.03.2024

Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg



Certificate No.: A3 50619113 0001

# Certificate Of Conformity

**License holder:** **SolaX Power Network Technology (Zhe jiang) Co., Ltd.**  
No.288 Shizhu Road, Tonglu Economic Development Zone  
Tonglu City, Zhejiang Province 310000,P.R. China

**Type of product:** PV-Inverter (Hybrid Inverter)

**Model:** X3-IES-4K, X3-IES-5K, X3-IES-6K, X3-IES-8K,  
X3-IES-10K, X3-IES-12K, X3-IES-15K,

**Firmware version:** DSP: 2.07; ARM: 2.03

**Standard:** **EN 50549-1:2019**  
Requirements for generating plants to be connected in parallel with distribution networks - Part 1: Connection to a LV distribution network -Generating plants up to and including Type B  
**EN 50549-1:2019+A1**  
Requirements for generating plants to be connected in parallel with distribution networks - Part 1:Connection to a LV distribution  
**EN 50549-10:2022**  
Requirements for generating plants to be connected in parallel with distribution networks - Part 10: Tests for conformity assessment of  
**2016/631 EU - (NC RfG)**  
COMMISSION REGULATION (EU) 2016/631 of 14 April 2016  
establishing a network code on requirements for grid connection of generators

**Report No.:** CN24PLIR 001

**Date of issue:** 16.03.2024

*The verification of conformity refers to the above mentioned product. This is to verify that the specimen is in conformity with the assessment requirement mentioned above. This verification does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.*



  
**Weichun Li**  
Certifier



Deutsche  
Akkreditierungsstelle  
D-ZE-14169-01-02

TÜV Rheinland LGA Products GmbH  
Am Grauen Stein 29 · 51105 Köln · Germany

 **TÜVRheinland®**  
Precisely Right.