



A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA201667

Date of Issue: 10 September 2020

Regulatory Definition: Non-Prescribed

Product Description: Stand-alone Battery Inverter (Off-grid)

General Modification:

Firmware version: 3.1.1.R

Software version: 3.1.1.R

Additional Models	Trade Name	Rating/Marking
SI4.4M-13	SMA	Battery: 48Vdc, 75A Output: 230V~ 50Hz 14.5A 3300W IP54, -25°C to +60°C, Class I
SI6.0H-13	SMA	Battery: 48Vdc, 103A Output: 230V~ 50Hz 20A 4600W IP54, -25°C to +60°C, Class I

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and RECS accreditation under the Queensland Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 10-09-20 201667/2